

Facility Name Greenfield Central Junior High School
 External Facility Id 2579
 Sample Collection Date 2020-03-14
 Lab Name Pace Analytical
 Analysis Date 2020-03-25
 Detection Limit 1.0 ppb*

Action Limit:
 15.0 ppb

*This is the lowest possible reading given this lab's equipment.

Fixture Code	Sample Type	Fixture Type	Fixture Location	Lead Results (ppb)
101	Initial	Faucet, Cold	KITCHEN	2.5
101	Flush	Faucet, Cold	KITCHEN	1.0
102	Initial	Ice Machine	kitchen	1.0
103a	Initial	Kitchen Kettle, Cold	KITCHEN	1.6
103a	Flush	Kitchen Kettle, Cold	KITCHEN	1.0
104b	Initial	Kitchen Kettle, Cold	KITCHEN	1.0
104b	Flush	Kitchen Kettle, Cold	KITCHEN	1.0
105	Initial	Coffee Maker	KITCHEN	1.0
106	Initial	Faucet, Cold	KITCHEN	1.1
106	Flush	Faucet, Cold	KITCHEN	1.0
107	Initial	Water Cooler	cafeteria	1.0
107	Flush	Water Cooler	cafeteria	1.0
108	Initial	Water Cooler	auditorium	1.0
108	Flush	Water Cooler	auditorium	1.0
109a	Initial	Water Cooler	e hall	1.0
109a	Flush	Water Cooler	e hall	1.0
110b	Initial	Water Cooler	e hall	1.0
110b	Flush	Water Cooler	e hall	1.0
111	Initial	Ice Machine	main hall	6.8
112	Initial	Faucet, Cold	main hall	1.2
113	Initial	Faucet, Cold	main hall	1.3
114a	Initial	Faucet, Cold	main hall	1.1
115b	Initial	Faucet, Cold	main hall	1.9

116c	Initial	Faucet, Cold	main hall	2.7
117a	Initial	Faucet, Cold	main hall	1.6
118b	Initial	Faucet, Cold	main hall	1.0
119c	Initial	Faucet, Cold	main hall	1.1
120a	Initial	Water Cooler	b hall	1.0
120a	Flush	Water Cooler	b hall	1.0
121b	Initial	Water Cooler	b hall	1.0
121b	Flush	Water Cooler	b hall	1.0
122	Initial	Faucet, Cold	b hall	1.9
123	Initial	Ice Machine	b hall	1.1
124	Initial	Faucet, Cold	main office area	3.1
125	Initial	Water Cooler	main office area	1.0
125	Flush	Water Cooler	main office area	1.0
126	Initial	Faucet, Cold	main office area	1.0
127a	Initial	Water Cooler	main hall	1.0
127a	Flush	Water Cooler	main hall	1.0
128b	Initial	Water Cooler	main hall	1.0
128b	Flush	Water Cooler	main hall	1.0
129	Initial	Faucet, Cold	main	1.3
130a	Initial	Water Cooler	gym hall	1.0
130a	Flush	Water Cooler	gym hall	1.0
131b	Initial	Water Cooler	gym hall	1.0
131b	Flush	Water Cooler	gym hall	1.0
133b	Initial	Water Cooler	2nd floor b hall	1.0
133b	Flush	Water Cooler	2nd floor b hall	1.0
134	Initial	Faucet, Cold	2nd floor main hall	1.0
135	Initial	Ice Machine	2nd floor main hall	1.6
136a	Initial	Water Cooler	2nd floor ehall	1.0
136a	Flush	Water Cooler	2nd floor ehall	1.0
137b	Initial	Water Cooler	2nd floor ehall	1.0
137b	Flush	Water Cooler	2nd floor ehall	1.0

Facility Name Greenfield Intermediate School
 External Facility Id 2593
 Sample Collection Date 2020-03-13
 Lab Name Pace Analytical
 Analysis Date 2020-03-17
 Detection Limit 1.0 ppb*

Action Limit: 15.0 ppb

*This is the lowest possible reading given this lab's equipment.

Fixture Code	Sample Type	Fixture Type	Fixture Location	Lead Results (ppb)
101	Initial	Water Cooler	b hall	1.0
101	Flush	Water Cooler	b hall	1.0
102a	Initial	Water Cooler	b hall	1.4
102a	Flush	Water Cooler	b hall	1.2
103b	Initial	Water Cooler	b hall	1.0
103b	Flush	Water Cooler	b hall	1.0
104a	Initial	Water Cooler	b hall	1.0
104a	Flush	Water Cooler	b hall	1.0
105b	Initial	Water Cooler	b hall	1.0
105b	Flush	Water Cooler	b hall	1.0
106a	Initial	Water Cooler	door 11 hall	1.0
106a	Flush	Water Cooler	door 11 hall	1.0
107b	Initial	Water Cooler	door 11 hall	1.1
107b	Flush	Water Cooler	door 11 hall	1.0
108	Initial	Faucet, Cold	c hall	4.5
109	Initial	Faucet, Cold	KITCHEN	2.2
109	Flush	Faucet, Cold	KITCHEN	1.0
110a	Initial	Sprayer	KITCHEN	1.0
111b	Initial	Kitchen Kettle, Cold	KITCHEN	8.2
111b	Flush	Kitchen Kettle, Cold	KITCHEN	1.0
112c	Initial	Kitchen Kettle, Cold	KITCHEN	5.6
112c	Flush	Kitchen Kettle, Cold	KITCHEN	1.0
113d	Initial	Kitchen Kettle, Hot	KITCHEN	4.1

113d	Flush	Kitchen Kettle, Hot	KITCHEN	1.0
114	Initial	Faucet, Cold	KITCHEN	1.9
114	Flush	Faucet, Cold	KITCHEN	1.0
115	Initial	Ice Machine	KITCHEN	1.0
116	Initial	Faucet, Cold	KITCHEN	2.8
116	Flush	Faucet, Cold	KITCHEN	1.0
117	Initial	Faucet, Cold	kitchen	1.2
117	Flush	Faucet, Cold	kitchen	1.0
118	Initial	Faucet, Cold	KITCHEN	4.1
118	Flush	Faucet, Cold	KITCHEN	1.0
119	Initial	Water Cooler	cafeteria	1.0
119	Flush	Water Cooler	cafeteria	1.0
120	Initial	Faucet, Cold	d hall	2.4
121	Initial	Faucet, Cold	d hall	1.0
122a	Initial	Water Cooler	2nd floor bhall - south	1.0
122a	Flush	Water Cooler	2nd floor bhall - south	10.8
123b	Initial	Water Cooler	2nd floor bhall - south	1.0
123b	Flush	Water Cooler	2nd floor bhall - south	14.3
124	Initial	Water Cooler	2nd floor bhall - south	1.0
124	Flush	Water Cooler	2nd floor bhall - south	1.0
125a	Initial	Water Cooler	2nd floor bhall - west	1.0
125a	Flush	Water Cooler	2nd floor bhall - west	1.0
126b	Initial	Water Cooler	2nd floor bhall - west	1.0
126b	Flush	Water Cooler	2nd floor bhall - west	1.1

Facility Name Greenfield-Central High School
 External Facility Id 2595
 Sample Collection Date 2020-03-14
 Lab Name Pace Analytical
 Analysis Date 2020-03-24
 Detection Limit 1.0 ppb*

Action Limit
 15.0 ppb

*This is the lowest possible reading given this lab's equipment.

Fixture Code	Sample Type	Fixture Type	Fixture Location	Lead Results (ppb)
101	Initial	Ice Machine	kitchen	1.0
102	Initial	Faucet, Cold	KITCHEN	3.1
102	Flush	Faucet, Cold	KITCHEN	1.0
103	Initial	Faucet, Cold	KITCHEN	1.0
103	Flush	Faucet, Cold	KITCHEN	1.0
104	Initial	Kitchen Kettle, Cold	KITCHEN	4.0
104	Flush	Kitchen Kettle, Cold	KITCHEN	1.0
105	Initial	Kitchen Kettle, Cold	kitchen	2.6
105	Flush	Kitchen Kettle, Cold	kitchen	1.0
106a	Initial	Kitchen Kettle, Cold	KITCHEN	3.3
106a	Flush	Kitchen Kettle, Cold	KITCHEN	1.0
107b	Initial	Kitchen Kettle, Hot	KITCHEN	1.0
107b	Flush	Kitchen Kettle, Hot	KITCHEN	1.0
108	Initial	Faucet, Cold	KITCHEN	1.0
108	Flush	Faucet, Cold	KITCHEN	1.0
109	Initial	Faucet, Cold	KITCHEN	2.5
109	Flush	Faucet, Cold	KITCHEN	1.0
110	Initial	Water Cooler	cafeteria	1.5
110	Flush	Water Cooler	cafeteria	1.0
111a	Initial	Water Cooler	hall 3	2.0
111a	Flush	Water Cooler	hall 3	4.0
112b	Initial	Water Cooler	hall 3	1.0
112b	Flush	Water Cooler	hall 3	1.7
113c	Initial	Water Cooler	hall 3	2.2

113c	Flush	Water Cooler	hall 3	1.7
114d	Initial	Water Cooler	hall 3	1.2
114d	Flush	Water Cooler	hall 3	3.1
115a	Initial	Water Cooler	hall 3	1.2
115a	Flush	Water Cooler	hall 3	1.8
116b	Initial	Water Cooler	hall 3	1.0
116b	Flush	Water Cooler	hall 3	2.2
117c	Initial	Water Cooler	hall 3	1.1
117c	Flush	Water Cooler	hall 3	2.2
118d	Initial	Water Cooler	hall 3	3.2
118d	Flush	Water Cooler	hall 3	4.2
119a	Initial	Faucet, Cold	e hall	1.0
120b	Initial	Faucet, Cold	e hall	1.2
121c	Initial	Faucet, Cold	e hall	1.1
122	Initial	Faucet, Cold	e hall	1.0
124b	Initial	Faucet, Cold	e hall	1.0
125c	Initial	Faucet, Cold	e hall	2.1
126	Initial	Ice Machine	e hall	1.0
127a	Initial	Faucet, Cold	e hall	1.0
128b	Initial	Faucet, Cold	e hall	1.0
129c	Initial	Faucet, Cold	e hall	1.0
130a	Initial	Faucet, Cold	e hall	1.0
131b	Initial	Faucet, Cold	e hall	1.0
132c	Initial	Faucet, Cold	e hall	1.0
133	Initial	Faucet, Cold	e hall	1.0
134a	Initial	Water Cooler	hall 2	1.3
134a	Flush	Water Cooler	hall 2	2.8
135b	Initial	Water Cooler	hall 2	1.0
135b	Flush	Water Cooler	hall 2	1.3
136c	Initial	Water Cooler	hall 2	1.0
136c	Flush	Water Cooler	hall 2	1.0
137d	Initial	Water Cooler	hall 2	1.0
137d	Flush	Water Cooler	hall 2	1.0

138	Initial	Faucet, Cold	hall 1	1.0
139a	Initial	Water Cooler	d wing	1.0
139a	Flush	Water Cooler	d wing	1.0
140b	Initial	Water Cooler	d wing	1.0
140b	Flush	Water Cooler	d wing	1.0
141a	Initial	Water Cooler	2nd floor d wing	1.0
141a	Flush	Water Cooler	2nd floor d wing	1.0
142b	Initial	Water Cooler	2nd floor d wing	1.0
142b	Flush	Water Cooler	2nd floor d wing	1.0
143a	Initial	Water Cooler	hall 2 main entry	2.0
143a	Flush	Water Cooler	hall 2 main entry	4.3
144b	Initial	Water Cooler	hall 1	1.0
144b	Flush	Water Cooler	hall 1	1.9
145c	Initial	Water Cooler	hall 2 main entry	1.0
145c	Flush	Water Cooler	hall 2 main entry	1.0
146d	Initial	Water Cooler	hall 2 main entry	1.0
146d	Flush	Water Cooler	hall 2 main entry	1.0
147a	Initial	Faucet, Cold	main office area	1.1
148b	Initial	Faucet, Cold	main office area	1.0
149	Initial	Faucet, Cold	hall 2	2.4
150	Initial	Faucet, Cold	hall 2	1.0
151a	Initial	Water Cooler	athletic wing	1.0
151a	Flush	Water Cooler	athletic wing	1.1
152b	Initial	Water Cooler	athletic wing	1.0
152b	Flush	Water Cooler	athletic wing	1.0
153	Initial	Faucet, Cold	athletic wing	20.7
154a	Initial	Water Cooler	athletic wing	1.0
154a	Flush	Water Cooler	athletic wing	1.0
155b	Initial	Water Cooler	athletic wing	1.0
155b	Flush	Water Cooler	athletic wing	1.0
156	Initial	Ice Machine	athletic wing	1.0
157	Initial	Ice Machine	athletic wing	1.0
158	Initial	Faucet, Cold	athletic wing	1.6

159	Initial	Faucet, Cold	athletic wing	217.0
160	Initial	Drinking Water Fountain	athletic wing	1.0
161a	Initial	Water Cooler	athletic wing	1.0
161a	Flush	Water Cooler	athletic wing	1.0
162b	Initial	Water Cooler	athletic wing	1.0
162b	Flush	Water Cooler	athletic wing	1.0
163a	Initial	Water Cooler	pool area	1.0
163a	Flush	Water Cooler	pool area	1.0
164b	Initial	Water Cooler	pool area	1.0
164b	Flush	Water Cooler	pool area	1.0
165	Initial	Faucet, Cold	pool area	1.1
166a	Initial	Water Cooler	pool area	1.0
166a	Flush	Water Cooler	pool area	1.0
167b	Initial	Water Cooler	athletic wing	1.0
167b	Flush	Water Cooler	athletic wing	1.0
168	Initial	Ice Machine	pool	1.0
169	Initial	Faucet, Cold	pool area	1.6

Facility Name Harris Elementary School
 External Facility Id 2597
 Sample Collection Date 2020-03-13
 Lab Name Pace Analytical
 Analysis Date 2020-03-19
 Detection Limit 1.0 ppb*

EPA Action Limit: 15.0 ppb

*This is the lowest possible reading given this lab's equipment

Fixture Code	Sample Type	Fixture Type	Fixture Location	Lead Results (ppb)
101	Initial	Faucet, Cold	administration room	6.1
102a	Initial	Water Cooler	1st grade	1.0
102a	Flush	Water Cooler	1st grade	1.0
103b	Initial	Water Cooler	1st grade	1.0
103b	Flush	Water Cooler	1st grade	1.0
104a	Initial	Water Cooler	1st grade	1.0
104a	Flush	Water Cooler	1st grade	1.0
105b	Initial	Water Cooler	1st grade	1.0
105b	Flush	Water Cooler	1st grade	1.0
106a	Initial	Water Cooler	door 15 hall	1.0
106a	Flush	Water Cooler	door 15 hall	1.0
107b	Initial	Water Cooler	door 15 hall	1.0
107b	Flush	Water Cooler	door 15 hall	1.0
108a	Initial	Drinking Water Fountain	gymnasium	1.0
108a	Flush	Drinking Water Fountain	gymnasium	1.0
109b	Initial	Drinking Water Fountain	gymnasium	1.0
110a	Initial	Water Cooler	door 15 hall	1.0
110a	Flush	Water Cooler	door 15 hall	1.0
111b	Initial	Water Cooler	door 15 hall	1.0
111b	Flush	Water Cooler	door 15 hall	1.0
112c	Initial	Water Cooler	door 15 hall	1.0
112c	Flush	Water Cooler	door 15 hall	1.0
113	Initial	Water Cooler	cafeteria	1.0

113	Flush	Water Cooler	cafeteria	1.0
114a	Initial	Water Cooler	office hall	1.0
114a	Flush	Water Cooler	office hall	1.0
115b	Initial	Water Cooler	office hall	1.0
115b	Flush	Water Cooler	office hall	1.0
116	Initial	Faucet, Cold	main office area	1.0
117	Initial	Faucet, Cold	main office area	1.0
118	Initial	Drinking Water Fountain	kindergarten hall	1.7
118	Flush	Drinking Water Fountain	kindergarten hall	2.1
119	Initial	Drinking Water Fountain	kindergarten hall	1.8
501	Initial	Other	Next to office- office hall	1.0
501	Flush	Other	Next to office- office hall	1.0

Facility Name Greenfield-Central Academy
 External Facility Id 10016
 Sample Collection Date 2020-03-12
 Lab Name Pace Analytical
 Analysis Date 2020-03-20
 Detection Limit 1.0 ppb*

*This is the lowest possible reading given this lab's equipment.

EPA Action Limit: 15.0 ppb

Fixture Code	Sample Type	Fixture Type	Fixture Location	Lead Results (ppb)
101	Initial	Ice Machine	back of conference room	1
102	Initial	Faucet, Cold	back of conference room	3.6
103	Initial	Water Cooler	entrance	1
103	Flush	Water Cooler	entrance	1.7
104	Initial	Ice Machine	commons	1
105	Initial	Faucet, Cold	commons	1
105	Flush	Faucet, Cold	commons	1
106	Initial	Water Cooler	commons	1
106	Flush	Water Cooler	commons	1
107	Initial	Faucet, Cold	commons	1.5

Facility Name Weston Elementary School
 External Facility Id 2609
 Sample Collection Date 2020-03-13
 Lab Name Pace Analytical
 Analysis Date 2020-03-20
 Detection Limit 1.0 ppb*

Action Limit: 15 ppb

*This is the lowest possible reading given this lab's equipment.

Fixture Code	Sample Type	Fixture Type	Fixture Location	Lead Results (ppb)
101	Initial	Faucet, Cold	main office area	1.0
102a	Initial	Water Cooler	1st grade hall	1.0
102a	Flush	Water Cooler	1st grade hall	1.4
103b	Initial	Water Cooler	1st grade hall	1.0
103b	Flush	Water Cooler	1st grade hall	1.0
104a	Initial	Water Cooler	1st grade hall	1.0
104a	Flush	Water Cooler	1st grade hall	1.0
105b	Initial	Water Cooler	1st grade hall	1.0
105b	Flush	Water Cooler	1st grade hall	1.1
106a	Initial	Water Cooler	1st grade hall	1.0
106a	Flush	Water Cooler	1st grade hall	1.0
107b	Initial	Water Cooler	1st grade hall	1.0
107b	Flush	Water Cooler	1st grade hall	1.0
108a	Initial	Water Cooler	2nd grade hall	1.0
108a	Flush	Water Cooler	2nd grade hall	1.0
109b	Initial	Water Cooler	2nd grade hall	1.0
109b	Flush	Water Cooler	2nd grade hall	1.0
110a	Initial	Water Cooler	kindergarten hall	1.0
110a	Flush	Water Cooler	kindergarten hall	1.0
111b	Initial	Water Cooler	kindergarten hall	1.0
111b	Flush	Water Cooler	kindergarten hall	1.0
112	Initial	Drinking Water Fountain	kindergarten hall	16.9
113	Initial	Drinking Water Fountain	kindergarten hall	1.0
114	Initial	Water Cooler	3rd grade	1.0

114	Flush	Water Cooler	3rd grade	1.0
115	Initial	Water Cooler	cafeteria	1.0
115	Flush	Water Cooler	cafeteria	1.0
116	Initial	Coffee Maker	kitchen	1.5
117	Initial	Faucet, Cold	kitchen	2.3
117	Flush	Faucet, Cold	kitchen	1.0
118	Initial	Kitchen Kettle, Cold	kitchen	CANCELLED
118	Flush	Kitchen Kettle, Cold	kitchen	1.0
119	Initial	Faucet, Cold	kitchen	1.3
119	Flush	Faucet, Cold	kitchen	1.0
120a	Initial	Water Cooler	next to gymnasium	1.0
120a	Flush	Water Cooler	next to gymnasium	1.0
121b	Initial	Water Cooler	next to gymnasium	1.0
121b	Flush	Water Cooler	next to gymnasium	1.0
122	Initial	Water Cooler	across from annex	1.0
122	Flush	Water Cooler	across from annex	1.0
123	Initial	Faucet, Cold	main office area	1.0
124	Initial	Ice Machine	main office area, workroom	1.0